

Reference No. : WTX23X05104740S
Applicant : COTRUST TECHNOLOGIES CO., LTD.
Address : 9/F, Block A Building 6, Shenzhen International
Innovation Valley, Dashi 1st Road, Nanshan District,
Shenzhen 518055,China
Manufacture : The same as above
Address : The same as above
Product : Programmable logic controller (PLC)
Model(s) : CTH3 C, CTH3 H, CTH3 PWR, CTH3 INT, CTH3 CAN,
CTH3 ECT, CTH3 PNT, CTH3 DIT, CTH3 DQT,
CTH3 DQR, CTH3 AIS , CTH3 AMS , CTH3 AIV,
CTH3 AIC, CTH3 AQS , CTH3 AIT, CTH3 AIR ,
CTH3 HSC , CTH3 HSP, CTH3 HUB, CTH3 BAT
Trade Name: : COTRUST
Ratings : 110V~ 50/60Hz 0.9A or 230V~ 50/60Hz 0.5A

Test Standards:

EN 61010-1:2010+A1:2019

EN 61131-2:2007

The above product has been tested by us with the listed standards and found in compliance with the Low Voltage Directive 2014/35/EU. It is possible to use CE marking to demonstrate the compliance with this Low Voltage Directive.

Safety requirements for electrical equipment for measurement, control, and laboratory use**Part 1: General requirements****Programmable controllers - Part 2: Equipment requirements and tests**

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the above mentioned EU Directive. Other relevant Directives have to be observed.

After preparation of the necessary technical documentation as well as the conformity declaration, the CE marking as shown below can be affixed on the equipment.



Manager: Jandy So

Date: 2023-07-03

The statement is based on a single evaluation of the sample of above mentioned product(s). It does not imply an assessment of the whole production.

Waltek Testing Group (Shenzhen) Co., Ltd.

Tel: +86-755-3366 3308

Fax: +86-755-3366 3309

Http://www.waltek.com.cn

E-mail: sem@waltek.com.cn